

Owner Name: _
Project Name: _
Project Address: _

Stormwater Pump Station Maintenance Plan

Year 1 and Beyond

- 1) Monitor the detention system following rain events to ensure that it drains completely within 48 to 72 hours, or per the design specifications. If the basin does not drain as designed, identify the cause. Promptly correct any issues to drain the facility as designed.
- 2) Monitor the water level in the downstream drainage facility to ensure that downstream capacity is not exceeded. Inspect and repair the pumps off override switch as necessary to resolve issues.
- 3) Inspect the one-way valve and remove any accumulated debris.
- 4) Evaluate systems or procedures in place to ensure that flooding will not occur as a result of power loss. Repair those systems and change procedures as necessary to prevent flooding.
- 5) At least once annually, provide the DISTRICT with a written report at least once per year and upon request by the DISTRICT showing the operation times, total hours of operation, and the amount of water pumped.

Submitted by: _____
(print name)

(signature)